



UL LLC  
1075 W Lambert Rd Suite B  
Brea, CA 92821

## Outdoor Distribution Test Report

Relevant Standards  
IES LM-79-2008, ANSI C82.77-2002

**Prepared For**  
**B-K Lighting Inc**  
Chris McCarthy  
40429 Brickyard Dr  
Madera, CA 93636-9515  
United States

**Catalog Number**  
**LTL-X45-LED**  
Order Number  
12033910  
Test Number  
12033910.05

Test Date

2017-11-14

Prepared By

William Escobar, Technician

Approved By

Eric Gaudreau, Senior Engineering Associate

The results contained in this report pertain only to the tested sample.  
This report shall not be reproduced, except in full, without written approval of Underwriters Laboratories.  
This report must not be used by the client to claim product certification, approval, or endorsement by  
NVLAP, NIST, or any agency of the Federal Government.



**Luminaire Description:** Decorative white metal housing with louvers and frosted lens  
**Lamp:** One (1) white LED with optic  
**Mounting:** Post  
**Ballast/Driver:** One (1) ECOdrive 561/S

#### Luminaire



#### Luminaire Characteristics

Luminous Diameter: 8.50 in.  
Luminous Height: 5.000 in.

#### Summary of Results

Roadway Classification: Type I, Medium  
Cutoff Classification: Noncutoff  
BUG Rating: B1 U4 G2

#### Test Conditions

Test Temperature: 25.3 °C  
Voltage: 120.0 VAC  
Current: 0.2796 A  
Power: 33.27 W  
Power Factor: 0.991  
Frequency: 60 Hz  
Current THD: 7.44 %

Tested in 30 planes left side, 30 planes right side, left and right averaged  
Vertical test increments are 2.5 degrees  
Test distance exceeds five times the greatest luminous opening of luminaire

Laboratory results may not be representative of field performance  
Ballast factors have not been applied



## Distribution - Goniophotometer

### Distribution Test Conditions

Temperature	Voltage	Current	Power	Power Factor	Frequency	Current THD
25.3 °C	120.0 VAC	0.2796 A	33.27 W	0.991	60 Hz	7.44 %

### Summary of Results


IES Roadway Classification:  
Cutoff Classification  
BUG Rating:

Type I, Medium  
Noncutoff  
B1 U4 G2

Total Lumen Output:  
Luminaire Efficacy:  
Maximum Candela:


2160 Lumens  
64.9 lm/w  
347 Candela

### ISO FootCandle Plot at 4 Feet





### Maximum Plane and Cone Plots of Candela



Vertical Plane Through

120 ° Lateral

Lateral Cone Through

72.5 ° Vertical

Maximum Intensity (Candlepower):

347 Candela

### Zonal Lumen Summary

Zone	Lumens	% of Luminaire	Zone	Lumens	% of Luminaire	Zone	Lumens	% of Luminaire
0-5	0.1	0.0%	60-65	132.7	6.1%	120-125	71.9	3.3%
5-10	0.7	0.0%	65-70	147.1	6.8%	125-130	63.8	3.0%
10-15	2.0	0.1%	70-75	159.9	7.4%	130-135	56.0	2.6%
15-20	4.0	0.2%	75-80	153.2	7.1%	135-140	47.9	2.2%
20-25	6.7	0.3%	80-85	134.4	6.2%	140-145	38.9	1.8%
25-30	10.0	0.5%	85-90	114.1	5.3%	145-150	28.5	1.3%
30-35	14.1	0.7%	90-95	98.8	4.6%	150-155	18.6	0.9%
35-40	25.3	1.2%	95-100	91.3	4.2%	155-160	11.2	0.5%
40-45	49.4	2.3%	100-105	88.4	4.1%	160-165	6.1	0.3%
45-50	83.1	3.8%	105-110	87.3	4.0%	165-170	2.9	0.1%
50-55	115.7	5.4%	110-115	85.4	4.0%	170-175	1.0	0.0%
55-60	129.5	6.0%	115-120	80.0	3.7%	175-180	0.1	0.0%



**IES "BUG" Rating**  
(Back Light, Uplight, Glare)  
Per IES TM-15-11



Luminaire Classification System (LCS)

LCS	Zone	Lumens	Luminaire %
FL	(0-30)	11.9	0.6%
FM	(30-60)	200.4	9.3%
FH	(60-80)	283.6	13.1%
FVH	(80-90)	119.4	5.5%
BL	(0-30)	11.7	0.5%
BM	(30-60)	216.6	10.0%
BH	(60-80)	309.3	14.3%
BVH	(80-90)	129.1	6.0%
UL	(90-100)	190.0	8.8%
UH	(100-180)	687.9	31.8%
Total		2160.0	100.0%
<b>BUG Rating</b>	<b>B1 U4 G2</b>		